FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Weyerhaeuser Paper Company

Date(s): June 1, 2016

 $\quad \text{Unit: } \underline{N/A}$

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S	Casing	Volts	Amps	Set	Actual	
Odorizer @ Williams Gate	12								Looked for AOCs
Block Valves on Cowlitz	12								Looked for AOCs
Rectifier / Fisher Ln @ RR Xing	12		-1295mv	392mv	6.01	2.2mv across shunt			Dial 7 of 9
Hwy 4	12		-1428mv	595mv					
Cascade & RR Xing	12		-1535mv	174mv					
Gas House	12		-1384mv	326mv					
Odorant Check	12								Reading = .64% AG / 5-15 LEL/UEL